

BEFORE THE BAY OF PLENTY REGIONAL COUNCIL

Resource consent application: 66758

IN THE MATTER	of the Resource Management Act 1991
AND	
IN THE MATTER	of an application under section 88 of the Act for resource consent to discharge stormwater to land Jellicoe Street, Te Puke
APPLICANT	Pukepine Sawmills (1998) Limited

SUPPLEMENTARY STATEMENT OF EVIDENCE OF ROB GWILYM FOR THE APPLICANT

- 1 My name is Rob Gwilym. I prepared a statement of evidence in respect of Pukepine Sawmills (1998) Limited's (**Pukepine**) application for resource consent to discharge stormwater from its site at Jellicoe Street, Te Puke dated 9 August 2019.
- 2 This supplementary statement of evidence provides responses to questions asked by Commissioner van Voorthuysen in respect of my primary statement of evidence.
- 3 Question: *"What actual reduction in site peak stormwater outflows has been achieved?"*
 - 3.1 At this time, there has been no actual reduction in site peak stormwater outflows. The stormwater management system has been designed to reduce the levels of contaminants in the stormwater leaving the site, which it has achieved.
 - 3.2 Pukepine is considering modifying the throughflow reticulation to allow for retention of peak flows for slow release. This is an ongoing process for Pukepine.
- 4 Question: *"How often is accumulated sediment removed from the catch pits and the two stormwater retention treatment vaults?"*
 - 4.1 Accumulated sediment is removed from the catch pits every two months unless physical observation indicates that an earlier clean out is required. Accumulated sediment is removed from the two stormwater sediment ponds every six months unless physical observation indicates that an earlier clean out is required.
- 5 Question: *"Where is the accumulated sediment disposed of?"*
 - 5.1 Accumulated sediment removed from the catch pits and the stormwater sediment ponds is disposed of at the Tirohia Landfill.
- 6 Question: *"What catch pit maintenance is undertaken?"*

- 6.1 As per paragraph 4.1 above, accumulated sediment is removed from the catch pits every two months unless physical observation indicates that an earlier clean out is required.
- 7 Question: *“Can you clarify if stormwater from the Purepine site is included within the current consent application or not?”*
- 7.1 The application site comprises 274-280 and part 290 Jellicoe Street, Te Puke legally described as Lots 2 and 3 DPS 77045 and part Lot 1 DPS 77045. Stormwater caught by the application includes runoff from all yard and circulation areas naturally draining (due to the falls across the site) towards the Factory Drain via the stormwater sediment ponds, and roof runoff from buildings at 274-280 Jellicoe Street (Lots 2 and 3 DPS 77045).

Rob Gwilym

16 August 2019